



Northbrook, Illinois • (847) 272 8800
Melville, New York • (516) 271-6200
Santa Clara, California • (408) 985-2400
Research Triangle Park,
North Carolina • (919) 549-1400
Camas, Washington • (360) 817-5500

CERTIFICATE OF COMPLIANCE

CERTIFICATE NUMBER: 121196 - E48340A
ISSUE DATE: November 12, 1996

Issued to: Square D Company
3700 6th Street SW
Cedar Rapids, IA 52404 USA

Report Reference: E48340, December 23, 1983

This is to Certify that
representative samples of: Molded Case Circuit Breakers and Ground Fault
Circuit Interrupters, Type QO and QOB, Series 2


Have been investigated by Underwriters Laboratories Inc. in accordance with the Standard(s)
indicated on this Certificate.

Standard(s) for Safety: UL 489, Molded Case Circuit Breakers and
Circuit Breaker Enclosures.
UL 943 Ground-Fault Circuit Interrupters.

Additional Information:

The product includes a switched pole and an unswitched pole and is rated 120 V ac, 15, 20, 25 and 30 A, Class A. Interrupting Ratings: 22kA max, 120 V, 60 Hz. Ampere Rating: 15-30. This product is intended to be installed in a Listed panel board or other suitable enclosure, to provide overcurrent protection of conductors and ground fault protection of personnel.

Only those products bearing the UL Listing Mark should be considered as being covered by UL's Listing and Follow-Up Service.

The UL Listing Mark generally includes four elements as follows: the name "Underwriters Laboratories Inc." in various forms and type styles, or abbreviations such as "Und. Lab. Inc.", or the symbol "UL in a circle" - ; the word "Listed"; a control number (may be alphanumeric) assigned by UL; and the product or category name (product identifier), as indicated in the appropriate UL Directory.

LOOK FOR THE UL LISTING MARK ON THE PRODUCT

Engineer: 
Underwriters Laboratories Inc.

Review Engineer: 
Underwriters Laboratories Inc.

Dorothy Trankowski

Craig Gatto