

# 产品认证证书

## II型自愿认证

证书编号: CQC2011010305491340

发证日期: 2021年03月18日

有效期至: 2031年03月18日

委托人名称 及注册地址	施耐德电气(中国)有限公司上海分公司 上海市普陀区绥德路669号
制造商名称 及注册地址	Schneider Electric Industries SAS 35 Rue Joseph Monier 92500 Rueil-Malmaison, France
生产企业名称 及生产地址	AIH - E. A. DU PHENIX 4 Rue Nicolas Appert 41700 Contres - France
产品名称和系列、 规格、型号	控制盒 XAC A, PBX P : Ui:600V ; Uimp:6kV ; Ith:10A ; AC-15:Ue/Ie:240V/3A ; DC-13:Ue/Ie:250V/0.27A ; IP65 ; 型号解释见附件
产品标准和技术要求	GB/T 14048.5-2017
认证模式	产品型式试验+初次工厂检查+获证后监督

上述产品符合 CQC12-000001-2020 认证规则的要求, 特发此证。

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

可通过扫描下方二维码或登录国家认监委网站(www.cnca.gov.cn)查验证书信息



授权签字人: 主任:

陈昕 陆楠

### 中国质量认证中心



# PRODUCT CERTIFICATION

## TYPE II CQC CERTIFICATION

CERTIFICATE NO.: CQC2011010305491340

Valid from: Mar.18,2021

Valid until: Mar.18,2031

**NAME AND REGISTERED ADDRESS OF THE APPLICANT** Schneider Electric (China) Co. Ltd. Shanghai Branch  
No. 669, Suide Road, Putuo District, Shanghai, P.R.China

**NAME AND REGISTERED ADDRESS OF THE MANUFACTURER** Schneider Electric Industries SAS  
35 Rue Joseph Monier 92500 Rueil-Malmaison, France

**NAME AND LOCATION OF THE FACTORY** AIH – E. A. DU PHENIX  
4 Rue Nicolas Appert 41700 Contres - France

**PRODUCT NAME, MODEL AND SPECIFICATION** Pendant Control Station  
XAC A, PBX P : Ui:600V ; Uimp:6kV ; Ith:10A ; AC-15:Ue/Ie:240V/3A ; DC-13:Ue/Ie:250V/0.27A ; IP65

**THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS** GB/T 14048.5-2017

**TYPE OF CERTIFICATION SCHEMES** Type Testing of Product + Initial Factory Inspection + Follow up Factory Inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC12-000001-2020.  
The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

The certificate information is available through the QR code below or CNCA's website: [www.cnca.gov.cn](http://www.cnca.gov.cn)



SIGNED BY:

PRESIDENT:

**CHINA QUALITY CERTIFICATION CENTRE**





# 产品认证证书

## II型自愿认证

附 录

第 1 页 共 2 页

证书编号: CQC2011010305491340

纸 号: 18034

型号解释:

<u>XACA</u> <u>PBXP</u> I	<u>21</u> <u>B</u> II	<u>7</u> <u>Y</u> III	<u>3</u> <u>01</u> IV
I	XAC-A 系列控制盒		PBXP 系列控制盒
II	按钮类型 20: 标准型 21: 带罩的		按钮类型 A: 标准型 B: 带罩的
III	按钮所对应的触头类型和数量 1: 1NO (ZB2-BE101) 2: 1NO(ZB2-BE101)+1NO(ZB2-BE101) 5: 1NO(ZB2-BE101)+1NC(ZB2-BE102) 7: 1NO(ZB2-BE101)+1NO(先 闭 合 ZB2-BE201)		按钮所对应的触头类型和数量 R: 1NO (ZB2-BE101) S: 1NO(ZB2-BE101) + 1NO(ZB2-BE101) T: 1NO(ZB2-BE101) + 1NC(ZB2-BE102) Y: 1NO(ZB2-BE101) + 1NO(先 闭 合 ZB2-BE201)
IV	急停按钮类型 空白: 没有急停按钮 3: 标准操动头(ZB5-AS834) 4: 触发动作的急停按钮(操作头 ZB5-AS834+触头模块 1NC ZB2-BE102)		急停按钮类型 空白: 没有急停按钮 01: 标准操动头(ZB5-AS834) 02: 触发动作的急停按钮(操作头 ZB5-AS834 + 触头模块 1NC ZB2-BE102)

注: XACA 和 PBXP 的差异仅仅在于前盖和后盖的颜色。产品结构和所有使用的原材料材质及所有技术参数完全等同。

注: 此附录与证书同时使用时有效。



## 中国质量认证中心

# 产品认证证书

## II型自愿认证

附 录

第 2 页 共 2 页

证书编号: CQC2011010305491340

纸 号: 18034

<u>XACA</u> <u>PBXP</u> I	<u>2I</u> <u>B</u> II	<u>7</u> <u>Y</u> III	<u>3</u> <u>0I</u> IV
I	XAC-A series Pendant Control Stations		PBXP series Pendant Control Stations
II	Type of push-button 20 : Standard 21: Booted		Type of push-button A : Standard B: Booted
III	Type and number of contacts under push-button 1 : 1NO (ZB2-BE101) 2: 1NO(ZB2-BE101)+1NO(ZB2-BE101) 5: 1NO(ZB2-BE101)+1NC(ZB2-BE102) 7: 1NO(ZB2-BE101) + 1NO(early make ZB2-BE201)		Type and number of contacts under push-button R : 1NO (ZB2-BE101) S : 1NO(ZB2-BE101) + 1NO(ZB2-BE101) T : 1NO(ZB2-BE101) + 1NC(ZB2-BE102) Y: 1NO(ZB2-BE101)+1NO(early make ZB2-BE201)
IV	Type of emergency switch Blank: Without emergency switch 3:Standard operating head (ZB5-AS834) 4:Trigger action operating head ( type : ZB5-AS834 + contact 1NC ZB2-BE102)		Type of emergency switch Blank: Without emergency switch 01: Standard operating head (ZB5-AS834) 02: Trigger action operating head ( type : ZB5-AS834 + contact 1NC ZB2-BE102)

Note: the difference between XAC A and PBX P is the colour of back cover and front cover only. The product structures & all the used raw material types and all technical data are same.

注：此附录与证书同时使用时有效。



## 中国质量认证中心