



Certificate of Compliance

Certificate: 1065010 (LR 92886-4)

Master Contract: 153555

Project: 70049962

Date Issued: October 21, 2015

Issued to: Schneider Electric USA, Inc.

Square D
3700 6th St SW
Cedar Rapids, IA 52404
USA
Attention: Manuel Salinas

The products listed below are eligible to bear the CSA Mark shown



R. Tateishi

Issued by: R. Tateishi, P. Eng.

PRODUCTS

CLASS 1432 01 - CIRCUIT BREAKERS - Moulded Case Type

Moulded case circuit breakers, Type QOU Series 3, 1- pole, 10-70A max, 120 or 120/240V ac max, 48V dc max; 2-pole, 10-70A max, 120/240V ac max, 48V dc max; 2-pole, 10-30A max, 240V ac max, 48V dc max; 3-pole, 10-60A max, 240V ac max, 48V dc max.

APPLICABLE REQUIREMENTS

CSA Standard C22.2 No. 5 - Molded-Case Circuit Breakers, Molded-Case Switches and Circuit-Breaker Enclosures



Supplement to Certificate of Compliance

Certificate: 1065010

Master Contract: 153555

The products listed, including the latest revision described below, are eligible to be marked in accordance with the referenced Certificate.

Product Certification History

Project	Date	Description
70049962	Oct 21, 2015	Revised construction of the base used on the 1- and 2-pole, 70A circuit breakers.
2734134	Jun 18, 2014	Revised construction of the stationary contacts used on the 3-pole, 35-60A, 10kA rated circuit breakers.
2654584	Aug 19, 2013	Revised construction of the arc stack used on the 3-pole, 35-60A, 10kA rated circuit breakers.
2546127	Jul 25, 2012	Revised construction of the 3-pole, 35-60A circuit breakers.
2416811	Apr 25, 2011	Revised construction of the arc stack used on the 3-pole, 15-60A, 10kA and 15-30A, 22kA rated circuit breakers.
2333627	Dec 6, 2010	Editorial revisions.
2314846	Jun 3, 2010	Revised construction of 1- and 2-pole, 25A breakers.
2290966	Apr 6, 2010	Change in base and cover material for 3-pole, 15-30A and 60A breakers, addition of arc stack to QOU310 and revised construction of 3-pole, 40 and 50A breakers.
2257770	Dec 22, 2009	Revised construction of the 1- and 2-pole, 35-60A, QOU-VH circuit breakers.
1767288	Feb 24, 2006	Addition of 120V ac rating for 1-pole circuit breakers.
1695250	Jul 27, 2005	Addition of 22kA HIC rating for 3-pole, 15-30A circuit breakers.
1680960	Jun 6, 2005	Addition of 22kA HIC rating and suffix "6190".

History

1199005 April 26, 2001 Addition of ring terminal connectors.

1097567 June 12, 2000 Addition of Cat No QOU230VH.

1065010 Mar. 3, 2000 Construction change allowing the removal of the DIN mounting slide mechanism. ORIGINALLY ISSUED AS 2500010928.

-90 Nov. 12, 1998 Alternate bimetal rawstock for the 70A breakers.

-14 May 11, 1992 Revised moveable contact.

-4 Jun 28, 1991 Type QOU, Series 3.