

Certificate of Compliance

Certificate Number 110403-E84967B
Report Reference E84967, December 18, 2002
Issue Date 2003 April 11

Page 1 of 1



Issued to: **Square D Company**

3700 6th Street S.W.
Cedar Rapids, IA. 52404 USA

*This is to certify that
representative samples of*

Molded Case Circuit Breakers
Type QOC series 1, two pole rated 150A - 200A

*Have been investigated by Underwriters Laboratories Inc.® in
accordance with the Standard(s) indicated on this Certificate.*

Standard(s) for Safety:

UL489. Molded Case Circuit Breakers, Molded Case Switches & Circuit Breaker Enclosures.

CSA C22.2 No. 5-02. Molded Case Circuit Breakers, Molded Case Switches & Circuit Breaker Enclosures.

Additional Information:


These are two pole circuit breakers rated 150-200A, 120/240V with the following interrupting rating:

Cat No. QO2XXX - 10,000 AIC


Cat. No. QO2XXXVH - 22,000 AIC


These breakers may be marked "HACR".

Only those products bearing the UL Listing Mark for the US and Canada should be considered as being covered by UL's Listing and Follow-Up Service meeting the appropriate requirements for US and Canada.

The UL Listing Mark for the US and Canada generally includes: the UL in a circle symbol with "C" and "US" identifiers:  (the word "LISTED"); a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product

Issued By: 
Lawrence R. Smith / Lead Engineering Associate
Underwriters Laboratories Inc.

Reviewed By: 
Antonio Romanace / Engineering Team Leader
Underwriters Laboratories Inc.