Northbrook, Illinois • (847) 272-8800 Melville, New York • (631) 271-6200 Santa Clara, California • (408) 985-2400 Research Triangle Park, North Carolina • (919) 549 1400 Camas, Washington • (360) 817-5500

Underwriters Laboratories Inc.®

CERTIFICATE OF COMPLIANCE

CERTIFICATE NUMBER: 031000-E2875 ISSUE DATE: October 3, 2000

	ISSUE DATE:	October 3, 2000	Page 1 of 3						
Issued to:	Square D Company 1601 Mercer Road lexington, KY. 40511 USA								
Report Reference:	E2875, March 4, 1998								
This is to Certify that representative samples of:	Enclosed Switches, types H221, 11321, 11361 and 11U361, suitable for use a service equipment. Catalog numbers may have suffix letters.								

Have been investigated by Underwriters Laboratories Inc.[®] in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 98, Enclosed Switches

Additional Information: See Addendum

Only those products bearing the UL Listing Mark should be considered as being covered by UL's Listing and Follow-Up Service.

The UL Listing Mark generally includes the following elements: the symbol UL in a circle: W with the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

LOOK FOR THE UL LISTING MARK ON THE PRODUCT Engineer: **Review Engineer:** take Killinger 6 Tom Skibbs Underwriters Laboratories Inc. Underwriters Laboratories Inc.

A not-for-profit organization dedicated to public safety and committed to quality service

Northbrook, Illinois • (847) 272-8800 Melville, New York • (631) 271 6200 Santa Clara, California • (408) 985-2400 Research Triangle Park, North Carolina • (919) 549-1400 Camas, Washington • (360) 817-5500



CERTIFICATE OF COMPLIANCE • ADDENDUM

CERTIFICATE NUMBER: 031000-E2875 **ISSUE DATE:** October 3, 2000

Page 2 of 3

This is to verify that representative samples of the product as specified on this certificate were tested according to the current UL requirements

RATINGS

Current: 30 A maximum

When used with Class J or R fuses, fusible switches are suitable for use Short Circuit: On circuits capable of delivering not more than 200,000 rms symmetrical Amperes.

> When used with Class H or K fuses, fusible switches are suitable for use On circuits capable of delivering not more than 10,000 rms symmetrical Amperes.

Unfused switches are suitable for use on circuits capable of delivering not More than

(a) 10,000 rms symmetrical amperes when protected by Class H or K fuses or

(b) 100,000 rms symmetrical amperes when protected by Class J, T or R fuses.

Engineer: \

Tom Skibbs Underwriters Laboratories Inc. Review Engineer:

Jake Killinger / 11B

Underwriters Laboratories Inc.

A not-for-profit organization dedicated to public safety and committed to quality service

Northbrook, Illinois • (847) 272-8800 Melville, New York • (631) 271-6200 Santa Clara, California • (408) 985-2400 Research Triangle Park, North Carolina • (919) 549-1400 Camas, Washington • (360) 817-5500



CERTIFICATE OF COMPLIANCE - ADDENDUM

CERTIFICATE NUMBER: 031000-E2875 Page 3 of 3 **ISSUE DATE:** October 3, 2000

This is to verify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

			Horsepower (+ indicates maximum rating)										
			Current	Alternating					Direct				
			Voltage	120	24	0	4	80	600		125	250	600
	Amps	Volts(max)		Phase		1 1	3	1	3	1	3	-	•
H221	30	240ac/250dc		.5,	1.5,	3,					2,	5	
				2+	3+	7.5+					3+		
H321	30	240ac/250dc		.5,	1.5,	3,					2, 3+	5	
				2+	3+	7.54	F				3+		
H361	30	600ac/600dc		.5,	1.5,	3,	3,	5,	3,	7.5	2,	5	10
				2+	3+	7.5+	7.5+	15+	10+	20+	3+		15+
HU361	30	600ac/600dc		2	5	10	7.5	20	10	30	3	5	15

Engineer: 4

Tom Skibbs Underwriters Laboratories Inc.

[kito

Review Engineer: Jake Killinger / 1/16

Underwriters Laboratories Inc.

A not-for-profit organization dodicated to public safety and committed to quality service