



Certificate of Compliance

Certificate: 70067732 (LR 92886-17)

Master Contract: 153555

Project: 70067732

Date Issued: 2016-03-21

Issued to: Schneider Electric USA, Inc.
Square D
3700 6th St SW
Cedar Rapids, Iowa 52404
USA
Attention: Manuel Salinas

The products listed below are eligible to bear the CSA Mark shown



Issued by: *Ronald Tateishi*
Ronald Tateishi

PRODUCTS

CLASS 1432 01 - CIRCUIT BREAKERS - Moulded Case Type

Circuit breakers, Type QOT, Series 2, 2-single pole circuit breakers in a common base, 15 through 30A, 120/240V ac max.

Notes:

1. The mechanism is trip free of the handle which assumes a mid position between "ON" and "OFF" upon automatic tripping.
2. These circuit breakers are uncompensated and calibrated to 40°C requirements.
3. These circuit breakers are suitable for use with copper and aluminum conductors.
4. These circuit breakers are suitable for reversed line and load connections.
5. These circuit breakers may be marked with a high current interrupting rating of 10,000 rms symmetrical A at 120/240V ac.

APPLICABLE REQUIREMENTS

CSA Standard C22.2 No. 5 - Molded-Case Circuit Breakers, Molded-Case Switches and Circuit-Breaker Enclosures



Supplement to Certificate of Compliance

Certificate: 70067732 (LR 92886-17)

Master Contract: 153555

The products listed, including the latest revision described below, are eligible to be marked in accordance with the referenced Certificate.

Product Certification History

Project	Date	Description
70067732	2016-03-21	Addition of an alternate plastic material (BMC 605) for the handles.
LR 92886-85	1998-03-02	Revised bimetal on the 25 and 30A breakers.
LR 92886-69	1997-01-27	Revised moveable contact.
LR 92886-20	1992-09-10	30A contact change.
LR 92886-17	1992-06-08	Original Certification.