

Northbrook, Illinois • (847) 272-8800
Melville, New York • (631) 271-6200
Santa Clara, California • (408) 985-2400
Research Triangle Park,
North Carolina • (919) 549-1400
Camas, Washington • (360) 817-5500



CERTIFICATE OF COMPLIANCE

CERTIFICATE NUMBER: 140601-E84905A
ISSUE DATE: June 14, 2001

Page 1 of 1

Issued to: Square D. Company
4800 Paris Road
Columbia, MO. 65202 USA

Report Reference: E84905, February 10, 1983

This is to Certify that
representative samples of: Molded-Case Circuit Breakers, Type QOM2


Have been investigated by Underwriters Laboratories Inc.® in accordance with the Standard(s)
indicated on this Certificate.

Standard(s) for Safety: UL 489, Molded-Case Circuit Breakers and Circuit Breaker Enclosures

Additional Information: These are two pole, common trip, uncompensated thermal circuit breakers,
rated 120/240 V ac, 100, 125, 150, 175, 200 and 225 A.

Current Interrupting Rating is maximum 22,000A at 120/240 V ac.

Only those products bearing the UL Listing Mark should be considered as being covered by
UL's Listing and Follow-Up Service.

The UL Listing Mark generally includes the following elements: the symbol UL in a circle:  with the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

LOOK FOR THE UL LISTING MARK ON THE PRODUCT

Engineer: *Lawrence R. Smith*
Lawrence R. Smith, Staff Eng. Assoc.
Underwriters Laboratories Inc.

Review Engineer: *Michael S. Mayes* /SA
Michael S. Mayes, Staff Eng. Assoc.
Underwriters Laboratories Inc.

A not-for-profit organization
dedicated to public safety and
committed to quality service