

Northbrook, Illinois • (847) 272-8800  
Melville, New York • (631) 271-6200  
Santa Clara, California • (408) 985-2400  
Research Triangle Park,  
North Carolina • (919) 549-1400  
Camas, Washington • (360) 817-5500



Underwriters Laboratories Inc.®

## CERTIFICATE OF COMPLIANCE

CERTIFICATE NUMBER: 071002-E6294F

ISSUE DATE: July 10, 2002

Page 1 of 1

Issued to: Square D Company  
1601 Mercer Rd.  
Lexington, KY. 40511

Report Reference: E6294, November 20, 1995

This is to Certify that  
representative samples of: Class 1130, Enclosed Panelboards. Type QO, Single Phase. Class CTL


Have been investigated by Underwriters Laboratories Inc.® in accordance with the Standard(s)  
indicated on this Certificate.

Standard(s) for Safety: UL 67, Panelboards

Additional Information: Ratings (Maximum)

Main Lug: 225A, 240V  
Main Breaker: 225A, 240V

Only those products bearing the UL Listing Mark should be considered as being covered by  
UL's Listing and Follow-Up Service.

The UL Listing Mark generally includes the following elements: the symbol UL in a circle:  with the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

**LOOK FOR THE UL LISTING MARK ON THE PRODUCT**

Engineer: *Susan Amir*  
Susan Amir, Project Handler III  
Underwriters Laboratories Inc.

Review Engineer: *Tom Skibbs*  
Tom Skibbs, Lead Engineering Associate  
Underwriters Laboratories Inc.