

CERTIFICATE OF COMPLIANCE

Certificate Number 20171005-E22182
Report Reference E22182-19730201
Issue Date 2017-OCTOBER-05

Issued to: Schneider Electric USA, Inc.
1010 Airpark Center Dr
Nashville TN 37217

This is to certify that representative samples of BUSWAYS AND ASSOCIATED FITTINGS
USL, CNL - Busway fittings, plug-in cable tap boxes, Type PBTB.

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 857 and CSA C22.2 NO. 27 Standard for BUSWAYS.
Additional Information: See the UL Online Certifications Directory at www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

