



CERTIFICATE OF COMPLIANCE

CERTIFICATE NUMBER: 131000-E33139D

ISSUE DATE: October 13, 2000

Page 1 of 2

Issued to: Square D Company
1601 Mercer Road
Lexington, KY. 40517 USA

Report Reference: E33139, January 24, 2000


This is to Certify that
representative samples of: Panelboards, typr NF, column type.

Have been investigated by Underwriters Laboratories Inc.® in accordance with the Standard(s)
indicated on this Certificate.


Standard(s) for Safety: UL 67, Panelboards

Additional Information: See Addendum

Only those products bearing the UL Listing Mark should be considered as being covered by
UL's Listing and Follow-Up Service.

The UL Listing Mark generally includes the following elements: the symbol UL in a circle:  with the word "LISTED"; a control
number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate
UL Directory.

LOOK FOR THE UL LISTING MARK ON THE PRODUCT

Engineer: 
Tom Skibbs
Underwriters Laboratories Inc.

Review Engineer: 
Jake Killinger
Underwriters Laboratories Inc.



CERTIFICATE OF COMPLIANCE - ADDENDUM

CERTIFICATE NUMBER: 131000-E33139D
ISSUE DATE: October 13, 2000

Page 2 of 2

This is to verify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

RATINGS

Current - 100A through 225 A maximum

Voltage -

480 Y/227 V ac, 3ph-4w or 1ph-3w

240 V ac, 3ph-3w or 1ph-2w

240/120 V ac delta, 3ph-4w

120/240 V, 1ph-3w

208/120 V ac, 3ph-4w or 1ph-3w

Short Circuit

Except for when series connected ratings are employed, these panelboards have SCCR's equal to the lowest interrupting rating of any installed circuit breaker, but not greater than:


100,000 rms sym. amperes at 240 V ac


65,000 rms sym. amperes at 480 Y/277 V ac

Maximum SCCR's when series connected ratings are employed are:

200,000 rms sym. amperes at 240 V ac

200,000 rms sym. amperes at 480 Y/277 V ac

Engineer: 
Tom Skibbs
Underwriters Laboratories Inc.

Review Engineer: 
Jake Killinger
Underwriters Laboratories Inc.