


INSTRUCTIONS SEAL TITE COVERS



When cable diameter is greater than *ring diameters "A"*—cut off flush with next larger diameter rings.

Under no circumstances cut off more than three rings.



wiring device division

Wiring Device Division HARVEY HUBBELL INCORPORATED Bridgeport, Connecticut 06602

FORM 552

