



Underwriters Laboratories Inc.®

Northbrook, Illinois • (847) 272-8800

Melville, New York • (516) 271-6200

Santa Clara, California • (408) 985-2400

Research Triangle Park,
North Carolina • (919) 549-1400

Camas, Washington • (360) 817-5500

CERTIFICATE OF COMPLIANCE

CERTIFICATE NUMBER: 121196 - E48340B
ISSUE DATE: November 12, 1996

Issued to: Square D Company
3700 6th Street SW
Cedar Rapids, IA 52404 USA

Report Reference: E48340, July 2, 1986

This is to Certify that representative samples of: Molded Case Circuit Breakers and Ground Fault Circuit Interrupters, Type QO and QOB, Series 2


Have been investigated by Underwriters Laboratories Inc. in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 489, Molded Case Circuit Breakers and Circuit Breaker Enclosures.
UL 943 Ground-Fault Circuit Interrupters.


Additional Information:


The product includes two switched poles and an unswitched pole and is rated 120/240 V, 15-60 A, 60 Hz, Class A. Interrupting Ratings: 10 kA, 120/240 V, 60 Hz. These products are intended to be installed in a Listed panel board or other suitable enclosure, to provide overcurrent protection of conductors and ground fault protection of personnel.

Only those products bearing the UL Listing Mark should be considered as being covered by UL's Listing and Follow-Up Service.

The UL Listing Mark generally includes four elements as follows: the name "Underwriters Laboratories Inc." in various forms and type styles, or abbreviations such as "Und. Lab. Inc.", or the symbol "UL in a circle" - ; the word "Listed"; a control number (may be alphanumeric) assigned by UL; and the product or category name (product identifier), as indicated in the appropriate UL Directory.

LOOK FOR THE UL LISTING MARK ON THE PRODUCT

Engineer: 
Underwriters Laboratories Inc.
Dorothy Trawkowska

Review Engineer: 
Underwriters Laboratories Inc.
Craig Gatto