

HOFFMAN ENCLOSURES, INC. 2100 Hoffman Way Minneapolis, MN 55303-1745, USA +1.763.421.2240 main

Declaration of Conformity

Issued by Manufacturer Hoffman Enclosures, Inc. 2100 Hoffman Way, Anoka, Minnesota 55303-1745, U.S.A. declare at our sole responsibility, that these devices are designed and constructed according to the fundamental safety and health requirements.

Enclosure Models:	UU*****	, UU*****W	(Bulletin U	J X1)

Equipment Description: Hoffman ULTRX, Type 4X

Enclosure Rating : CSA Type 3, 3R, 4, 4X, 12

Enclosure Certification: CSA C22.2 No. 14

PRODUCTS

CLASS - 3211 07 - INDUSTRIAL CONTROL EQUIPMENT-Miscellaneous Apparatus

For details related to rating, size, configuration, etc. reference should be made to the CSA Certification Record or the descriptive report. For details related

Polymeric enclosures, Bulletin UX-1, ULTRX, water-tight and dust-tight (CSA Type 4, 4X, 12, 3 and 3R), max size 40.25 in by 32.50 in by 13 in.

Note: Window adhesive materials were not evaluated by CSA.

Applicable Standards:

CSA C22.2 No. 14 – Industrial Control Equipment CAN/CSA C22.2 No. 94 - Special Purpose Enclosures

Authorized by:

Glin Kampa

Glen Kampa

<u>5/22/2020</u> (today's date)

Date

Senior Regulatory Engineer

Subject to Change Without Notice

DOC: CERT-00248-B



Certificate of Compliance

Certificate: 1783564 (042186 C 000)

Project: 70177548

Issued to: Hoffman Enclosures Inc. 2100 Hoffman Way Anoka, Minnesota 55303-1745 United States Master Contract: 151630

Date Issued: April 4, 2018

The products listed below are eligible to bear the CSA Mark shown



Issued by: Payam Rafieian Payam Rafieian

PRODUCTS

CLASS - 3211 07 - INDUSTRIAL CONTROL EQUIPMENT-Miscellaneous Apparatus

For details related to rating, size, configuration, etc. reference should be made to the CSA Certification Record or the descriptive report For details related

Polymeric enclosures, Bulletin UX-1, ULTRX, water-tight and dust-tight (CSA Type 4, 4X, 12, 3 and 3R), max size 40.25 in by 32.50 in by 13 in.

Note: Window adhesive materials were not evaluated by CSA.

APPLICABLE REQUIREMENTS

CSA C22.2 No. 14 - Industrial Control Equipment CAN/CSA C22.2 No. 94 - Special Purpose Enclosures