



Certificate of Compliance

Certificate: 1459263

Master Contract: 153555 (LR 40970)

Project: 70059070

Date Issued: 2016-01-12

Issued to: Schneider Electric USA, Inc.
Square D
3700 6th St SW
Cedar Rapids, Iowa 52404
USA
Attention: Manuel Salinas

The products listed below are eligible to bear the CSA Mark shown



Issued by: *Ronald Tateishi*
Ronald Tateishi

PRODUCTS

CLASS 1432 01 - CIRCUIT BREAKERS - Moulded Case Type

Circuit breakers, 1-pole, 70A max, 277V ac max; 1-pole, 30A max, 347V ac max; 2- and 3-pole, 125A max, 480Y/277V ac max, 2- and 3-pole, 100A max, 600Y/347V ac max, Catalogue No Prefix ED, EG and EJ, Series 1.
Circuit breakers, 1-pole, 30A max, 347V ac max, Catalogue No Prefix EK, Series 1.

APPLICABLE REQUIREMENTS

CSA Standard C22.2 No. 5 - Molded-Case Circuit Breakers, Molded-Case Switches and Circuit-Breaker Enclosures



Supplement to Certificate of Compliance

Certificate: 1459263

Master Contract: 153555 (LR 40970)

*The products listed, including the latest revision described below,
are eligible to be marked in accordance with the referenced Certificate.*

Product Certification History

Project	Date	Description
70059070	2016-01-12	Revised construction of the 35-70A circuit breakers and the deletion of the 110A, 600Y/347V ac rated circuit breakers.
70011990	2014-09-22	Update to Report 1459263 to cover addition of line terminal fiber.
2679806	2013-11-19	Addition of an alternate base and cover material (Premi-Jet 1101V manufactured by Pre-Mix) for the 15-30A circuit breakers.
2543226	2012-10-12	Addition of the use of Premi-Glas 2207-22 CR-SX.
2406133	2011-03-28	Addition of an arc horn to the 15-30A circuit breakers.
1978242	2007-11-13	Revised construction of EGB36110.
1803919	2006-06-16	Addition of alternate base and cover material for 15-30A breakers and addition of 600Y/347V ac rating to the 15-110A breakers.
1459263	2003-07-31	Original Certification. Moulded case circuit breaker, E-frame