

CERTIFICATE OF COMPLIANCE

Certificate Number 20180827-E131840
Report Reference E131840-19990805
Issue Date 2018-AUGUST-27

Issued to: Schneider Electric USA, Inc.
1010 Airpark Center Dr
Nashville TN 37217

This is to certify that representative samples of PANELBOARDS, MODULAR
See Addendum Page for Models

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 67 Standard for Panelboards
Additional Information: See the UL Online Certifications Directory at www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number 20180827-E131840
Report Reference E131840-19990805
Issue Date 2018-AUGUST-27

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Models/Product:

Panelboard module, Series EZM

Cat. No. (+)(+)(+++)

EZM315125M10, EZM113125X, EZM114125, EZM114125X, EZM115125, EZM115125X, EZM313125, EZM313125X, EZM314125, EZM314125X, EZM315125, EZM315125X, EZM116125, EZM116125X, EZM316125, EZM316125X, EZM313125CA, EZM313125CAX, EZM314125CA, EZM314125CAX, EZM315125CA, EZM315125CAX, EZM316125CA, EZM316125CAX, EZM313125M10, EZM313125M10X, EZM314125M10, EZM314125M10X, EZM315125M10, EZM315125M10X, EZM316125M10, EZM316125M10X, EZM112225, EZM112225X, EZM113225, EZM113225X, EZM114225, EZM114225X, EZM115225, EZM312225, EZM312225X, EZM313225, EZM313225X, EZM314225, EZM314225X, EZM315225, EZM312225CA, EZM312225CAX, EZM313225CA, EZM313225CAX, EZM314225CA, EZM314225CAX, EZM315225CA, EZML113125, EZML113125X, EZML114125, EZML114125X, EZML115125, EZML115125X, EZML313125, EZML313125X, EZML314125, EZML314125X, EZML315125, EZML315125X, EZML116125, EZML116125X, EZML316125, EZML316125X, EZML313125CA, EZML313125CAX, EZML314125CA, EZML314125CAX, EZML315125CA, EZML315125CAX, EZML316125CA, EZML316125CAX

(+) - Also includes catalog number Prefix EZMR instead of EZM, indicating ringless meter covers or with EZMH indicating ringless meter covers with factory installed horn bypass, Cat. No. MMHB. Horn bypass Cat. No. MMHB may be factory or field installed in catalog numbers with Prefix EZMR or EZMH. See File E10582, Vol. M, Sec. 7 for description.


(++) - Also includes Suffix X which indicates 1200 A rated horizontal cross bus.

(+++)- Also includes suffix CU which indicates all copper bus.

(++++)- Also includes suffix H which indicates Meter socket neutral wire factory installed. See illustration 11.

Catalog number Suffix CA indicates device is factory assembled to Phases A and C only and cannot be field converted to Phase B.

Catalog numbers with multiple suffixes, may have their suffix in random order.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

