



CERTIFICATE OF COMPLIANCE

CERTIFICATE NUMBER: 110100 - E84967
ISSUE DATE: January 11, 2000

Page 1 of 1

Issued to: Square D Company
3700 6th Street SW
Cedar Rapids, IA 52404-3069 USA

Report Reference: E84967, October 12, 1999

This is to Certify that representative samples of: Arc Fault Circuit Interrupters, Branch /Feeder Type
Type QO\B -AFI
HOM-AFI

Have been investigated by Underwriters Laboratories Inc.® in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL489, Molded Case Circuit Breakers and Circuit Breaker Enclosures
UL1699, Arc Fault Circuit Interrupters


Additional Information: These are Single Pole Circuit Breakers with a built in Arc Fault Module. They are rated 15-20 A. Current interrupting rating as follows: 10,000 A, 120Vac, 1ph,50/60 Hz. Uses wires rated as follows: 60 or 75° C.

Notes: May be marked:


"Listed HACR Type"


HOM, QOB & QO Type Breakers may be marked "SWD"

Only those products bearing the UL Listing Mark should be considered as being covered by UL's Listing and Follow-Up Service.

The UL Listing Mark generally includes the following elements: the symbol UL in a circle:  with the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

LOOK FOR THE UL LISTING MARK ON THE PRODUCT

Engineer: 
L.R. Smith
Underwriters Laboratories Inc.

Review Engineer: 
Jeffrey H. Hidaka
Underwriters Laboratories Inc.