

**IEC****IECEE**

Ref. Certif. No.

CN73577

**IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME****CB TEST CERTIFICATE**

Product

AC Contactors

Name and address of the applicant

Schneider Electric Industries SAS  
35 Rue Joseph Monier 92500 Rueil-Malmaison, France

Name and address of the manufacturer

Schneider Electric Industries SAS  
35 Rue Joseph Monier 92500 Rueil-Malmaison, France

Name and address of the factory

Schneider Electric France  
2 Rue du Pont Vert, 27100 Le Vaudreuil, France*Note: When more than one factory, please report on page 2* Additional information on page 2

Ratings and principal characteristics

See the Appendix

Trademark (if any)

Schneider Electric

Customer's Testing Facility (CTF) Stage used

N/A

Model / Type Ref.

LC1K06, LC1K09, LC1K12, LC1K16, LC2K06, LC2K09, LC2K12, LC2K16, LC7K06, LC7K09, LC7K12, LC8K06, LC8K09, LC8K12, LP1K06, LP1K09, LP1K12, LP2K06, LP2K09, LP2K12, LP4K06, LP4K09, LP4K12, LP5K06, LP5K09, LP5K12, LC1K09004, LC1K12004, LC2K09004, LC2K12004, LC7K09004, LC7K12004, LC8K09004, LC8K12004, LP1K09004, LP1K12004, LP2K09004, LP2K12004, LP4K09004, LP4K12004, LP5K09004, LP5K12004, LC1K09008, LC7K09008, LP1K09008, LP4K09008, LC1K06..6..S207, LC1K09..6..S207, LC1K0986..S207, LC1K12..6..S207, LC1KT206..S207, LC1K06....S335, LC1K09....S335, LC1K12....S335, LC2K12....S335, LC1K16....S335, LC1K098..S335, LC1KT20..S335;

Additional information (if necessary may also be reported on page 2)

A sample of the product was tested and found to be in conformity with

IEC 60947-1:2020; IEC 60947-4-1:2023

As shown in the Test Report Ref. No. which forms part of this Certificate

00901-CB2025CQC-123335

**CHINA QUALITY CERTIFICATION CENTRE CO., LTD.**Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China  
Tel: +86-10-83886666 Fax: +86-10-83886282  
website: <http://www.cqc.com.cn>

Date: Sep.29,2025

Signature:

Xie ZhaoXu

**IEC****TECEE**

®

™

Ref. Certif. No.

CN73577

Name of the factory	Address of the factory
PT. Schneider Electric Manufacturing Batam	Jl Beringin Lot 4, Lot 208, Lot 15, Lot 16, DAN Lot 16A BIP Muka Kuning Kel.Muka Kuning Kec. Sungai Beduk – Batam, Indonesia

Additional information (if necessary)

Date: Sep.29,2025

Signature:

Xie ZhaoXu

LC1K06, LC1K09, LC1K12, LC1K16, LC2K06, LC2K09, LC2K12, LC2K16, LC7K06, LC7K09, LC7K12, LC8K06, LC8K09, LC8K12, LP1K06, LP1K09, LP1K12, LP2K06, LP2K09, LP2K12, LP4K06, LP4K09, LP4K12, LP5K06, LP5K09, LP5K12, LC1K09004, LC1K12004, LC2K09004, LC2K12004, LC7K09004, LC7K12004, LC8K09004, LC8K12004, LP1K09004, LP1K12004, LP2K09004, LP2K12004, LP4K09004, LP4K12004, LP5K09004,

LP5K12004, LC1K09008, LC7K09008, LP1K09008, LP4K09008, LC1K06..6..S207,

LC1K09..6..S207, LC1K0986..S207, LC1K12..6..S207, LC1KT206..S207, LC1K06....S335,

LC1K09....S335, LC1K12....S335, LC2K12....S335, LC1K16....S335, LC1K098..S335, LC1KT20..S335

Ui:690V;

Uimp:8kV

Ith: Spring terminal 16A, and other is 20A;

LC1K06, LC2K06, LC7K06, LC8K06, LP1K06, LP2K06, LP4K06, LP5K06, LC1K06..6..S207, LC1K06....S335:

AC-3/ AC-3e: Ue/Ie: 230V/6.3A, 400V/4.9A, 440V/6A, 690V/3.8A;

AC-4: Ue/Ie: 230V/5.25A, 400V/4.09A, 440V/5A, 690V/3.17A;

AC-1: Ue/Ie: 230V/400V/440V/690V/16A(Spring terminal), 230V/400V/440V/690V/20A (other terminal);

LC1K09, LC2K09, LC7K09, LC8K09, LP1K09, LP2K09, LP4K09, LP5K09, LC1K09004, LC2K09004, LC7K09004, LC8K09004, LP1K09004, LP2K09004, LP4K09004, LP5K09004, LC1K09008, LC7K09008,

LP1K09008, LP4K09008, LC1K09..6..S207, LC1K0986..S207, LC1K09....S335, LC1K098..S335,

LC1KT206..S207, LC1KT20..S335:

AC-3/ AC-3e: Ue/Ie: 230V/8.5A, 400V/8.5A, 440V/9A, 690V/4.9A;

AC-4: Ue/Ie: 230V/7.09A, 400V/7.09A, 440V/7.5A, 690V/4.1A;


AC-1: Ue/Ie: 230V/400V/440V/690V/16A(Spring terminal), 230V/400V/440V/690V/20A(other terminal);

## Additional information (if necessary)

Date:

Sep.29,2025

Signature:



Xie ZhaoXu

LC1K12, LC2K12, LC7K12, LC8K12, LP1K12, LP2K12, LP4K12, LP5K12, LC1K12004, LC2K12004, LC7K12004, LC8K12004, LP1K12004, LP2K12004, LP4K12004, LP5K12004, LC1K12...6..S207, LC1K12...S335, LC2K12...S335:

AC-3/ AC-3e: Ue/Ie: 230V/11.3A, 400V/11.5A, 440V/12A, 690V/4.9A;

AC-4: Ue/Ie: 230V/9.42A, 400V/9.59A, 440V/10A, 690V/4.1A;

AC-1: Ue/Ie: 230V/400V/440V/690V/16A(Spring terminal), 230V/400V/440V/690V/20A(other terminal);

LC1K16, LC2K16, LC1K16...S335:

AC-3/ AC-3e: Ue/Ie: 230V/15A, 400V/15.5A, 440V/16A, 690V/4.9A;

AC-4: Ue/Ie: 230V/12.5A, 400V/12.92A, 440V/12.34A, 690V/4.1A;

AC-1: Ue/Ie: 230V/400V/440V/690V/16A(Spring terminal), 230V/400V/440V/690V/20A(other terminal);

Us:

LC1K,LC2K(50/60Hz): 12 V, 20V, 24V, 36 V, 42V, 48V, 60V,100V,110 V,

115V, 120V, 127V, 150V, 180V, 200/208V, 220/230V, 230V, 230/240V,

256V, 277V, 380/400V, 400V, 400/415V, 440V, 480V, 500V, 575V, 600V, 660/690V;

LC1K,LC2K(50Hz): 24V, 42V, 48V, 230V;

LC7K,LC8K(50/60Hz): 24V, 42V, 48V, 100V, 110V, 115V, 127V, 200V,220V, 230/240V;

LP1K,LP2K(DC): 12V, 20V, 24V, 36V, 40V, 48V, 60V, 72V, 80V, 100V, 110 V,

125V, 155V, 174V, 200V, 220V, 230V, 240V, 250V;

LP4K,LP5K(DC): 12V, 20V, 24V, 36V, 48V, 60V, 72V, 110V, 120V;

LC1K...S207,LC1KT...S207(DC): 24V, 72V, 110V;

LC1K...S335, LC1KT...S335(50/60Hz): 24V, 230V;

LC1K...S335, LC2K12...S335 (DC): 12V, 24V;

## Additional information (if necessary)

Date:

Sep.29,2025

Signature:



Xie ZhaoXu

IEC

TECEE

®

™

Ref. Certif. No.

CN73577

Pole: 3P/4P;IP20(from front face only);

Auxiliary contacts: (body)

Ith:10A;AC-15: Ue/Ie: 120V/6A, 690V/1.04A;

DC-13: Ue/Ie: 125V/0.55A, 600V/0.1A;

LC./LP.K..10: 1 NO, LC./LP.K..01: 1 NC;

Page 3 of 3

Additional information (if necessary)

Date:

Sep.29,2025

Signature:

谢肇煦

Xie ZhaoXu